

PHOTOMETRIC TEST REPORT


TERRA ROUND 28 LED

astro

TERRA ROUND 28 LED


astro

LIGHT EFFICIENCY:




OUTPUT: 52.8 lm

LIGHT QUALITY:



PEAK: 63.7 cd

COLOR TEMPERATURE:



POWER: 1.8 W

PF: 0.42



Tracking number: [n/a](#)

Product name:

Terra Round 28 LED

Item number:


1201005

Date and time:

29/04/2021 12:19:40


Description:

IP67 Outdoor LED Ground light




CIE 1931
x: 0.435
y: 0.409



SPECTRA



POWER





COLOR DETAILS



TM30: 87.6

CRI: 85.7 (R1-R8)



CRI R values, only R1-R8 are used to calculate final CRI value

R1	R2	R3	R4	R5	R6	R7	R8	R9	R10	R11	R12	R13	R14	R15
84.5	93.1	97.0	84.8	84.8	92.6	84.9	63.5	16.2	84.2	85.4	76.5	86.8	99.0	75.9


TM30 C values, 16 binned values out of total of 99 C values

C1	C2	C3	C4	C5	C6	C7	C8	C9	C10	C11	C12	C13	C14	C15	C16
82.0	85.1	85.1	93.7	93.9	95.6	89.7	94.0	90.1	84.7	86.4	88.2	88.2	81.6	81.4	79.6

CQS Q values

Q1	Q2	Q3	Q4	Q5	Q6	Q7	Q8	Q9	Q10	Q11	Q12	Q13	Q14	Q15
79.6	94.4	88.2	85.0	86.5	87.0	87.2	90.4	95.5	93.3	90.7	88.2	86.2	74.0	76.1

CQS: 85.4



COLOR PARAMETERS

Color temperature	Color rendering index	Red component	Color fidelity	Color gamut	Color quality scale	Color coordinate cie 1931	Color coordinate cie 1931	Color coordinate	Color coordinate	Color deviation from black body
CCT	CRI	CRI R9	TM30 Rf	TM30 Rg	CQS	x	y	u	v	Δuv
3079 K	85.7	16.2	87.6	95.0	85.4	0.435	0.409	0.247	0.349	0.0021







Rf 87.6

Fidelity index Rf


Rg 95.0

Gammut index Rg

Hue Bin	Graphic shifts (%)		
	R _f	Chroma	Hue
1	82	-10%	0%
2	85	-7%	5%
3	85	-3%	7%
4	94	-1%	3%
5	94	-2%	2%
6	96	-1%	-1%
7	90	-6%	-3%
8	94	-3%	2%
9	90	-4%	5%
10	85	-3%	8%
11	86	1%	9%
12	88	7%	-1%
13	88	3%	-8%
14	82	3%	-15%
15	81	-4%	-11%
16	80	-8%	-14%



BEAM DETAILS



Beam intensities from 1-20m

1m	2m	3m	4m	5m	6m	7m	8m	9m	10m	11m	12m	13m	14m	15m	16m	17m	18m	19m	20m
3.3ft	6.6ft	9.8ft	13.1ft	16.4ft	19.7ft	23ft	26.2ft	29.5ft	32.8ft	36.1ft	39.4ft	42.7ft	45.9ft	49.2ft	52.5ft	55.8ft	59.1ft	62.3ft	65.6ft
62lx	15lx	7lx	4lx	2lx	2lx	1lx	1lx	1lx	1lx	1lx	0lx	0lx	0lx	0lx	0lx	0lx	0lx	0lx	0lx
5.7fcd	1.4fcd	0.6fcd	0.4fcd	0.2fcd	0.2fcd	0.1fcd	0.1fcd	0.1fcd	0.1fcd	0fcd	0fcd	0fcd	0fcd	0fcd	0fcd	0fcd	0fcd	0fcd	0fcd

Intensities in 0° c-plane

0°	2°	4°	6°	8°	10°	12°	14°	16°	18°	20°	22°	24°	26°	28°	30°	32°	34°	36°	38°
61.8	62.4	62.4	62.5	62.7	62.4	59.1	55.9	51.2	45.6	40.8	40.0	39.3	36.8	33.3	29.2	21.1	12.9	9.6	8.7
100%	101%	101%	101%	101%	101%	96%	91%	83%	74%	66%	65%	64%	60%	54%	47%	34%	21%	15%	14%

Intensities in 90° c-plane

0°	2°	4°	6°	8°	10°	12°	14°	16°	18°	20°	22°	24°	26°	28°	30°	32°	34°	36°	38°
61.8	61.4	61.4	61.5	61.7	61.9	62.6	63.3	63.0	61.5	60.1	46.5	32.5	22.2	15.9	9.7	9.3	9.2	8.8	8.3
100%	99%	99%	100%	100%	100%	101%	102%	102%	100%	97%	75%	53%	36%	26%	16%	15%	15%	14%	13%

Intensities in 180° c-plane


0°	2°	4°	6°	8°	10°	12°	14°	16°	18°	20°	22°	24°	26°	28°	30°	32°	34°	36°	38°
61.8	62.4	62.4	62.5	62.7	62.4	59.1	55.9	51.2	45.6	40.8	40.0	39.3	36.8	33.3	29.2	21.1	12.9	9.6	8.7
100%	101%	101%	101%	101%	101%	96%	91%	83%	74%	66%	65%	64%	60%	54%	47%	34%	21%	15%	14%

Intensities in 270° c-plane

0°	2°	4°	6°	8°	10°	12°	14°	16°	18°	20°	22°	24°	26°	28°	30°	32°	34°	36°	38°
61.8	61.4	61.4	61.5	61.7	61.9	62.6	63.3	63.0	61.5	60.1	46.5	32.5	22.2	15.9	9.7	9.3	9.2	8.8	8.3
100%	99%	99%	100%	100%	100%	101%	102%	102%	100%	97%	75%	53%	36%	26%	16%	15%	15%	14%	13%

Beam angle 50%	Field angle 10%	Cutoff angle 2,5%	Intensity ratio in 120° cone	Intensity ratio in 90° cone
53.5°	88.7°	121°	97.1%	88.4%


ISO CANDELA DIAGRAM



10%	6 cd
20%	12 cd
30%	19 cd
40%	25 cd
50%	31 cd
60%	37 cd
70%	43 cd
80%	49 cd
90%	56 cd

Conditions:
Number of c-planes: 8
Candela at center: 62 cd

ISO LUX DIAGRAM



3%	18.5m lx
5%	30.9m lx
10%	61.8m lx
30%	0.185 lx
50%	{LUX_10M50} lx

Conditions:
Number of c-planes: 8
Lux at center: 0.618 lx

Lux distribution on a surface when lamp is mounted at 10 meters from the surface.


UGR

GLARE EVALUATION ACCORDING TO UGR

p Ceiling		70	70	50	50	30	70	70	50	50	30
p Walls		50	30	50	30	30	50	30	50	30	30
p Floor		20	20	20	20	20	20	20	20	20	20
Room size X Y		Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis				
2H	2H	15.1	15.8	15.2	16.1	16.3	14.1	14.8	14.2	15.0	15.2
	3H	14.9	15.7	15.3	15.9	16.1	13.8	14.7	14.2	14.9	15.1
	4H	14.9	15.6	15.3	15.9	16.1	13.8	14.6	14.2	14.8	15.1
	6H	14.9	15.5	15.2	15.8	16.2	13.8	14.4	14.1	14.7	15.1
	8H	14.8	15.4	15.1	15.8	16.2	13.7	14.4	14.1	14.7	15.1
	12H	14.8	15.4	15.1	15.7	16.2	13.7	14.3	14.0	14.7	15.1
4H	2H	14.9	15.7	15.3	15.9	16.2	13.9	14.7	14.3	14.9	15.1
	3H	14.9	15.5	15.2	15.9	16.3	13.9	14.5	14.2	14.8	15.3
	4H	14.8	15.3	15.2	15.8	16.3	13.8	14.3	14.2	14.8	15.3
	6H	14.7	15.3	15.2	15.6	16.0	13.7	14.3	14.2	14.6	15.0
	8H	14.7	15.2	15.2	15.5	15.9	13.6	14.2	14.2	14.5	14.9
	12H	14.6	15.0	15.1	15.4	15.9	13.6	14.0	14.1	14.4	14.9
8H	4H	14.7	15.2	15.2	15.5	15.9	13.6	14.2	14.2	14.5	14.9
	6H	14.6	15.0	15.1	15.4	16.0	13.6	14.0	14.1	14.4	15.0
	8H	14.6	14.9	15.1	15.4	16.1	13.6	13.9	14.1	14.4	15.0
	12H	14.5	14.8	15.1	15.3	15.9	13.5	13.8	14.1	14.3	14.9
12H	4H	14.6	15.0	15.1	15.4	15.9	13.6	14.0	14.1	14.4	14.9
	6H	14.6	14.9	15.1	15.4	16.1	13.6	13.9	14.1	14.4	15.0
	8H	14.5	14.8	15.1	15.3	15.9	13.5	13.8	14.1	14.3	14.9
Variation of the observer position for the luminaire distance S											
S = 1.0H		3.7 / -3.3					1.7 / -2.7				
S = 1.5H		6.1 / -6.3					3.6 / -6.2				
S = 2.0H		7.9 / -9.0					5.3 / -8.9				
Standard table		n/a					n/a				
Correction summand		n/a					n/a				
Corrected glare indices referring to 52.8 lm total luminous flux											

COEFFICIENTS OF UTILIZATION

Ceiling reflectance	80				70				50			30			10			0
Wall reflectance	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
Floor reflectance	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	20	0
RCR	(RCR: Room Cavity Ratio) Room Values are expressed as percentage of Lumens delivered to the task surface																	
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	113	110	107	105	110	108	106	103	104	102	100	100	98	97	96	95	94	92
2	107	102	98	94	105	100	96	93	97	94	91	94	91	89	91	89	87	85
3	101	95	89	85	99	93	88	85	90	86	83	88	85	82	86	83	80	79
4	96	88	82	78	94	87	82	77	85	80	77	83	79	76	81	77	75	73
5	91	82	76	72	89	81	76	72	80	75	71	78	74	70	76	72	70	68
6	86	77	71	67	85	76	71	66	75	70	66	73	69	65	72	68	65	63
7	82	73	67	62	81	72	66	62	71	65	62	69	65	61	68	64	61	59
8	78	69	62	58	77	68	62	58	67	62	58	66	61	58	65	60	57	56
9	75	65	59	55	73	64	59	55	63	58	54	62	58	54	62	57	54	53
10	71	61	56	52	70	61	55	52	60	55	51	59	55	51	59	54	51	50



ZONAL LUMEN SUMMARY

0°-10°	10°-20°	20°-30°	30°-40°	40°-50°	50°-60°	60°-70°	70°-80°	80°-90°
5.94 lm	15.9 lm	15.5 lm	6.82 lm	4.65 lm	2.53 lm	0.922 lm	0.280 lm	0.072 lm


90°-100°	100°-110°	110°-120°	120°-130°	130°-140°	140°-150°	150°-160°	160°-170°	170°-180°
0.024 lm	0.025 lm	0.030 lm	0.028 lm	0.034 lm	0.037 lm	0.032 lm	0.022 lm	0.008 lm

FLICKER


FLICKER CURVE (COMPLETE SAMPLED FLICKER)



FLICKER FRAME (FRAME OF ONE FLICKER PERIOD)



FLICKER FFT (FREQUENCY SCOPE OF FLICKER CURVE)



FLICKER RESULTS:

Flicker frequency:	142.86 Hz
Flicker index:	0
Flicker percentage:	0.93 %
SVM: (Visual flicker)	0.02

FLICKER CONDITIONS:

Sample rate:	20000 samples/second
--------------	----------------------